

Specification

Parameter	Typical	Min/Max	Otherwise
NCV kcal/kg	6000–7000 kcal/kg	5850 kcal/kg min	Rejected as per Discharge Port analysis
Total Moisture	7–9%	10% max	
Volatile Matter	24%	21% min, 32% max	
Sulphur	0.6%	0.8% max	
Ash	13%	15% max	
HGI (ADB)	50 – 55	45 min, 70 max	
Size	0–50mm	0% >75 mm Max. 2% >50 mm Min.30% > 5 mm	